

## David Lukaczer

---

**From:** Debi Cler <debi@townzen-consulting.com>  
**Sent:** Tuesday, May 16, 2023 2:51 PM  
**To:** David Lukaczer  
**Subject:** SPR-23-009 USNR - Building Notes

David,

Here are SPR-23-009 Building Notes:

- All Geotech recommendations and requirements will be required to be implemented into the design of the structure additions.

Additional Note: There are no new parking spaces noted. Therefore, this project will not need to comply with IBC Sec 429 EV Infrastructure. It will also not need to comply with WSEC C411 Solar Readiness.

Let me know if you have any questions.

Thank you,

*Debi Cler – Plans Examiner*

***Townzen & Associates, Inc.***

221 Kenyon St. NW, Suite 102, Olympia, WA 98502 | P: 360-890-2747

[debi@townzen-consulting.com](mailto:debi@townzen-consulting.com) | [www.townzen-consulting.com](http://www.townzen-consulting.com)



*This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error, please notify the system manager. This message contains confidential information and is intended only for the individual named. If you are not the named addressee you should not disseminate, distribute or copy this e-mail. Please notify the sender immediately by e-mail if you have received this e-mail by mistake and delete this e-mail from your system. If you are not the intended recipient you are notified that disclosing, copying, distributing or taking any action in reliance on the contents of this information is strictly prohibited.*