

**ADDENDUM 2  
TO THE CONTRACT PROVISIONS AND CONTRACT PLANS**

**FOR**

**CITY OF WOODLAND  
FILTERS 2 AND 3 RESTORATION AND MEDIA REPLACEMENT**

**G&O #23607**

**ISSUED THIS DATE: TUESDAY, DECEMBER 19, 2023**

**BID SUBMITTAL: 1:00 P.M. (LOCAL TIME) ON  
WEDNESDAY, DECEMBER 20, 2023  
CITY OF WOODLAND  
230 DAVIDSON AVENUE  
WOODLAND, WASHINGTON 98674**



**Bidder shall acknowledge receipt of this Addendum on Page P-5 of the Proposal.**

---

**TO PROSPECTIVE BIDDERS:**

The attention of all prospective bidders on the above project is directed to the following additions and modifications to the Contract Provisions and Contract Plans.

**I. ADDITIONS, MODIFICATIONS, AND/OR DELETIONS TO THE PROPOSAL**

**ITEM 1:**

Page P-5 Proposal

**REVISE** the third paragraph as follows:

“The undersigned furthermore agrees to complete all activities requiring a coating inspector within a combined period ~~for both filters~~ of ~~40~~ 30 working days. These activities include blasting, prime coat application, stripe coat application, intermediate coat application, finish coat application, and testing. Liquidated damages in the amount of \$1,200 per day will be assessed for each and every working day beyond the contract time allowed for the completion of the activities requiring a coating inspector.”

**II. ADDITIONS, MODIFICATIONS, AND/OR DELETIONS TO THE TECHNICAL SPECIFICATIONS**

**ITEM 1:**

Page 09950-9, Specification Section 09950-2.3, INTERIOR FILTER COATING

**REVISE** the first paragraph as shown below (added text is italicized, deleted text is shown as strike out):

“The interior coating system shall be suitable for potable water service (~~AWWA D102, ICS 3 modified for zinc rich primer for entire interior surface~~). The interior system shall include:”

**ITEM 2:**

Page 09950-10, Specification Section 09950-2.4, EXTERIOR FILTER COATING

**REVISE** the first paragraph as shown below (added text is italicized, deleted text is shown as strike out):

“~~The exterior coating system shall meet the requirements of AWWA D102, OCS 6, as modified herein.~~ The exterior system shall include:”